

Talentum® 16501

IR² Flame Detector Stainless Steel

The Talentum® dual Infra-Red (IR²) Flame Detector is designed to protect areas where open fires may be expected and detects almost all flames, including hydrocarbon fires with $4.3\mu m$ emissions through to invisible fires such as hydrogen.

The IR^2 Flame Detector is sensitive to flickering, low frequency (I-I5Hz) infra-red radiation emitted by flames during combustion even if the lens is contaminated by a layer of oil, dust, water, vapour or ice.

This detector has two IR sensors which respond to different IR wavelengths in order to discriminate between flames and spurious sources of radiation. False alarms from flickering sunlight are avoided by a combination of filters and signal processing techniques.

The Talentum $^{\oplus}$ IR 2 detector has selectable output options of relay contacts or 4-20mA signal, as standard.

Features

- High immunity to false sources
- Tolerant of fumes, vapours, dust and mist
- Suitable for indoor areas
- · Unaffected by convection currents, draughts or wind
- Proven response to multiple fuel types
- Multi-spectrum detection
- Selectable output options
- Selectable response speed
- Selectable sensitivity levels
- Built in auto and manual test
- Low current consumption
- Fast response to fire



Applications

- Compressor Stations
- Chemical Plants
- Tunnels
- Waste Recycling
- Nuclear Power Sites
- Engine Rooms
- Spray Booths

- Pharmaceutical Production
- Military Applications
- Marine Industry
- Coal Handling
- Printing
- LNG/LPG Production

Accessories

07127 Stainless Steel Adjustable Mount (304) 12545 Stainless Steel Weather Shield (304) 16091 Portable Flame Detector Tester







Talentum® 16501

Mechanical Specification

| • | | |
|---------------------|-------------------------------|--|
| Housing Material | Stainless Steel 3 6 Housing | |
| Housing Colour | Natural | |
| Dimensions | 142(H) x 108(W) x 82(D) mm | |
| Weight | 2.1kg | |
| Cable Gland Entries | 2 x 20mm | |
| Wiring | 1.0 to 4.0mm ² | |

Electrical Specification

| ziecei ieur opeemenen | | | |
|-----------------------|----------------------------------|--|--|
| Supply Voltage | 14 to 30Vdc | | |
| Quiescent Current | 8mA, RL2 energised | | |
| | 4mA, current loop, RL2 off | | |
| | 3mA, RL2 off | | |
| Alarm Current | 28mA, RLI & RL2 energised | | |
| | 20mA, current loop, RL1 & 2 off | | |
| | 9mA, RLI energised | | |
| Power Up Time | 2 seconds max. | | |
| Test Signal Voltage | 14 to 30Vdc | | |
| Relay Outputs | Normally Open or Normally Closed | | |
| - Programmable | Latching or Non-latching | | |
| - Ratings: Current | I.OA Max. | | |
| Voltage | 50Vdc Max. | | |
| Power | 30W Max. | | |
| | (Note: Resistive Loads Only) | | |

Environmental

| Operating Temperature | -10°C to +55°C |
|-----------------------|--------------------|
| Storage Temperature | -20°C to +65°C |
| Relative Humidity | 95% Non condensing |
| IP Rating | IP66 |

Performance

| Range | - Class I* | 0.1 m ² n-heptane at 25m | | |
|------------|---------------|-------------------------------------------------------------------------------|--|--|
| | - Class 3 | 0.1 m ² n-heptane at 12m (see EN54:10 for sensitivity settings) | | |
| Field of \ | View | 90° min. Cone | | |
| Operatir | ng Wavelength | | | |
| Band - IR | | 0.75 to 2.7μm | | |
| | | | | |

ffe

FFE Limited 9 Hunting Gate, Hitchin Hertfordshire, SG4 0TJ UK

t +44 (0) 1462 444 740 e sales@ffeuk.com


w www.ffeuk.com

Response Characteristics - High Sensitivity

| Fuel | Flame Size m (ft) | Distance m (ft) | Average Response time (seconds) |
|-------------------------------------|--------------------------|--------------------|---------------------------------|
| n-Heptane* (Yellow flame) | 0.3 × 0.3 (I × I) | 25 (82) | 12 |
| Methylated Spirit* (Clear flame) | 0.5 × 0.5 (1.6 × 1.6) | 25 (82) | 25 |
| Hydrogen (non-visible flame) | 0.1 × 0.5 (0.3 × 1.6) | 12 (39) | 8 |

^{*} has been tested and approved at Class I


Field of View




To meet the requirements of EN54:10 clause 5.4, where the ratio of the response points Dmax: Dmin should not exceed 1.41, the horizontal and vertical viewing angles max should not exceed $\pm 30^{\circ}$.

Flame Detector

Mounting Bracket





Installation Recommendations

Please refer to our User Manual for mounting and wiring instructions. The installation of Talentum flame detectors should be undertaken in accordance with the recognised national or international standards and codes of practice.

Specifications and wiring information are provided for information only and are believed to be accurate. FFE Ltd assumes no responsibility for their use. Data and design are subject to change without notice. Installation and wiring instructions are shipped with the products and should always be used for actual installation. For more information, contact your Sales Representative.

Document Part No: 24-0247-05

